

## Emergency Action Checklist

Action	Standard	y/n
Are all exits unobstructed and is the path to an exit at least 28 inches wide at all points?	1910.36	
Are all exits marked by an exit sign with lettering that is at least 5 inches high and illuminated by a reliable light source??	1910.37(b)	
Are doors or passageways that are not an exit, but could be mistaken as an exit, marked as "NOT AN EXIT," or its actual character?	1910.37(b)(5)	
Has the employer developed a written emergency action plan for emergencies such as fires or tornados?	1910.38(b)	
Does the plan include procedures for reporting a fire or other emergency? (i.e. manual pull box, public address, radio or telephone)	1910.38(c)(1)	
Does the employer provide a distinctive and recognizable alarm system capable of being perceived above ambient noise or light levels to alert employees of need for emergency action?	1910.165(b)	
Does the plan include procedures for emergency evacuation and exit route assignments?	1910.38(c)(2)	
Does the plan include procedures to be followed by employees who remain to operate critical plant operations before they evacuate?	1910.38(c)(3)	
Does the plan include procedures to account for all employees after evacuation?	1910.38(c)(4)	
Does the plan include procedures to be followed by employees performing rescue or medical duties?	1910.38(c)(5)	
Does the plan include the name of the person who may be contacted by employees who need more information about the plan?	1910.38(c)(6)	
Has an emergency response plan been developed and implemented to handle anticipated emergencies? <i>Emergency response</i> is a response by employees from outside the immediate area to an uncontrolled release of a hazardous substance.	1910.120(q)(1)	
Do employees engaged in an emergency response to a hazardous substance, presenting a potential inhalation hazard, wear positive pressure self-contained breathing apparatus, until air monitoring indicates a decreased level of respiratory protection is adequate?	1910.120(q)(3)(iv)	
Is emergency care available at the worksite from a designated member of the workforce trained in first aid or a trained emergency service provider and available within 3-4 minutes?	1910.151(b)	
Is there an eye-wash that will provide a continuous flow of water to both eyes for at least 15 minutes within 50 feet or ten seconds of an area where corrosive liquids or materials are handled?	1910.151(c)	
When portable fire extinguishers are available for employee use, has the employer provided an (annual) educational program for each user on the general principles of fire extinguisher use and the hazards of incipient stage fire fighting or informed employees that they are not allowed to use the fire extinguishers and are required to evacuate?	1910.157(g)(1)	
Have all employees who are expected to respond to medical emergencies as part of their job responsibilities had the hepatitis B vaccination made available to them and been trained to understand how to use the PPE to protect against bloodborne diseases?	1910.1030	
Are employees trained in first aid and identified by the employer as responsible for rendering medical assistance as part of his/her job duties provided bloodborne pathogens training?	1910.1030(g)(2)	

Please take appropriate action to address any "no" response